

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/ 342

DATED: 20/06/2024

To,

The President/ Secretary
Siddhartha Kunj CGHS Ltd.
Plot No.17, Sector-7, Dwarka,
New Delhi-110075

Subject:- Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Siddhartha Kunj CGHS Ltd. Located at Plot No.17, Sector-7, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter No. SKGH/820/2024/01, dated 18/05/2024 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 12/06/2024 in the presence of Mr. Shyam sunder Sharma (Manager) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The internal road around the building found encroached / blocked.
2. Stairs found partially blocked.
3. Hose reel hose & hydrants found nonfunctional.
4. MOEFA found nonfunctional
5. Terrace pumps found nonfunctional.
6. Basement found being used for parking/ storage. It must not be used for any purpose as affidavit given by the society management.
7. Dully fill form J & K are not submitted.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.


(Addl Carg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.