

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 345

Dated: 21/06/2024

To,

Assistant Engineer (E)- III,
PWD EMESD South West,
Janakpuri Super Speciality Hospital,
C-2B, Janakpuri, New Delhi- 110058.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Super Specialty Hospital Wing of DDU Hospital, C-2B, Janak Puri., New Delhi-110058.

Sir,

This has reference to your letter No. F.No. 24(8)/AE (E)-III/PWD HMED SW/2024-25/80, dated 29.05.2024, on the subject cited above. In this connection, it is to inform you that the inspection of above said hospital building has been carried out by officers concerned of this department on 11.06.2024 in the presence of Dr. Reecha.

During the course of inspection, it was observed that the hospital building Comprised of Basement (parking/services), ground plus five upper floors. However, the following shortcomings were observed: -

1. Road all around the hospital building was found blocked by parking shed.
2. No's of staircase found locked and blocked
3. Fire Check doors found removed at some places.
4. Ventilation system found not functional at basement and lift lobby.
5. Hose reels/Hydrant found provided but not functional.
6. MOEFA found provided but not functional.
7. P.A System found provided but not functional
8. Fire pumps found provided but not functional in auto mode.
9. Exit Signages found removed at some places.
10. Sprinkler system in basement floor found non-functional.
11. Pressurization system for lift shaft & lift lobby found non-functional.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
dc h

Copy to:-

1. The Medical Superintendent, Janakpuri Super Specialty hospital, C-2B, Janakpuri, New Delhi-110058.
2. The Executive Engineer (E) PWD HSW DAP Lines, Vikas Puri, New Delhi- 18.