

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 350

DATED: 24 06 /2024

To,

The President,  
Ministry of External Affairs CGHS Ltd  
Sector – 02, Dwarka, New Delhi.

**Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Ministry of External Affairs CGHS Ltd located at, Sector – 02, Dwarka, New Delhi.**

Sir,

Please refer to email dated 05/06/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 19/06/2024 in the presence of Mr Gurmeet Singh (A.E CPWD) from fire safety point of view.

**During the course of inspection followings shortcoming are observed:-**

1. Hoses & branches found missing at some places.
2. MOEFA & PA system found nonfunctional.
3. Pumps at terrace level found nonfunctional on auto mode.
4. Communication system in lift car found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Yours faithfully,

  
(Abdul Garg)  
Director  
Delhi Fire Service  
20/6/24

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.