



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Industrial/SZ/2024/ 355

Dated: 24/06/2024

To,

The Authorized Signatory,
M/s T & T Motors Pvt. Ltd.,
GA- 2, B-1 Extension, Mohan Cooperative Industrial Estate,
New Delhi-44.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s T & T Motors Pvt. Ltd., located at GA- 2, B-1 Extension, Mohan Cooperative Industrial Estate, New Delhi-44.

Sir,

With reference to your email dated 12.06.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 20.06.2024 in the presence of Mr. Girija Pandey (Manager) and it was observed that the building is comprised of Two tier Basements + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire check door (FCD) found removed in basement.
2. Ventilation system in basement found non functional.
3. No exhaust provisions at ground & upper floors.
4. Hose reels found non functional.
5. Automatic Fire Detection and Alarm System (ADAS) found non functional.
6. Manual Operated Electrical Fire Alarm System (MOEFA) found non functional.
7. Sprinkler system found non functional.
8. Internal & yard hydrant found non functional.
9. Fire pumps found non functional.
10. Terrace fire pump not in auto mode.
11. Exit & lift sinages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

24/06/24

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.