



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F. 6. / DFS / MS / BP / 2024/ 361

Dated: 27/06/2024

To,

The Medical Superintendent,
B M Gupta Hospital Pvt. Ltd.,
H-11 to 15, Uttam Nagar,
New Delhi -110059.

Sub:- Submission of documents of B.M. Gupta Hospital Pvt. Ltd. Centre, situated at H – 11 to 15, Uttam Nagar, New Delhi – 110059.

Sir,


Please refer your letter No. Nil dated Nil received on 22.05.2024 on the subject cited above. In this connection it is to inform you that as built plan of said hospital, as provided by you, has been examined and observed following shortcomings:

1. Name and Address of the premises are not mentioned on the plan.
2. The plan is not to scale.
3. Width of access road is not provided.
4. Width of staircases is not meeting the requirement of UBBL – 2016.
5. Width of corridor is not meeting the requirement of UBBL – 2016.
6. Width of exit, patient / ward rooms is not meeting the requirement of UBBL – 2016.
7. Staircases, serving from basement, are not segregated on ground floor.
8. Entry to staircases is not through Fire Check Doors.
9. Dead end travel distance from corridor is not meeting the requirement of UBBL – 2016.
10. Fire protection arrangements such as underground fire tank, overhead fire tank, hose reel, fire extinguishers etc. as stipulated in NBC-Part-4 are not marked on the plan.
11. One ward is shown on terrace, but its floor plan is not provided.

Therefore, plan is returned to you in original with request to rectify above shortcomings and re-submit the plan for further consideration in the matter.

Encl.: As above

Yours faithfully


26/6/24

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

PH 011-23412025

Copy to:

The Medical Superintendent, Nursing Homes,
Directorate General of Health Services,
Govt. of NCT of Delhi (Nursing Home Cell),
3rd Floor, Delhi Government Dispensary Building,
S-1, School Block, Shakarpur, Delhi – 110092.