

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/ 358

Dated: - 26/06/2024

To,

The Principal,
Green Valley International Public School,
205, Deepak Vihar, Najafgarh, New Delhi- 110043

Sub: - Regarding renewal of fire safety certificate in r/o Green Valley International Public School at 205, Deepak Vihar, Najafgarh, New Delhi- 110043.

Sir,


Please refer to your letter No. GVIPS/FC/2024 dated 08.05.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 13.06.2024 in presence of Sh. Kapoor Singh.

During the course of inspection found that the school building comprised of ground plus three upper floors. However, the following shortcomings have been observed: -

- 1 First Aid hose reels found provided but not functional.
- 2 Terrace Fire pump Capacity of 450 LPM found provided but not functional in auto mode.
- 3 Overhead water storage tank found capacity of 5,000 ltrs. against requirement capacity of 10,000 ltrs.
- 4 Exit signage found removed.
- 5 Sports Complex & swimming pool is newly constructed. You are advised to submit the drawings of Sports Complex to access the fire safety measures.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully



(Atul Garg)

Director

Delhi Fire Service

Copy to: -

The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.