



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZI 360

Dated: 26/06/2024

To,

The Principal,
M.C. Primary School,
Basti Sarai- 1st, Delhi-110035.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary School, Basti Sarai- 1st, Delhi-35.
Madam,

This has reference to your application no. nil dated 03.06.2024 received via outdoor diary no. 2409 dated 04.06.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 19.06.2024 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Abhishek Meena (Teacher) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Width of staircases found 1.60 m & 1.10 m against the required width of 1.50 m each.
2. First aid hose reels provided but not functional.
3. Terrace level pump found not provided.
4. Exit signage's not provided.
5. Electric meter under the staircase has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

26/6/24

Copy to:-

1. Director of Education, MCD, Civic Centre, Delhi.