

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 26/06.. /2024

No. F.6/DFS/MS/School/2024/SZ/354
To

The Principal,
MCD Nigam Pratibha School No -1, (Boys)
Dr. Ambedkar Nagar, Sector-1 (Tigri) New Delhi 110062

Sub: Regarding issuance of FSC in r/o MCD Nigam Pratibha School No -1, (Boys)
Dr. Ambedkar Nagar, Sector-1 (Tigri) New Delhi 110062

Sir,

This has reference to your letter no nil dated 03/06/2024, received through outdoor diary no 4456 dated 16/08/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.06.2024 in the presence of Mr. Rajendra Kumar (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel provided but found nonfunctional.
2. Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
3. The Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Directorate of Education, MCD, Civic Centre, Minto Road, New Delhi-110002