

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/2024/ 356

Dated: 29/06/2024

To,

The Director,  
Lady Harding Medical College &  
Associated Hospital, New Delhi.

Sub: Regarding fire clearance of Oncology block at Lady Harding Medical College and associated Hospital, at Shaheed Bhagat Singh Marg, New Delhi.

Sir,

This has reference to your mail id <directorlhmc@gmail.com> dated 27.05.2024, on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 13/06/24 in the presence of Sh. Ranjeet (JE) and the following shortcomings were observed.

1. Detector found non functional at some offices.
2. Electrical shaft are not sealed at floor level.
3. PA system found non functional.
4. Pressurization of lift lobby & shaft found non functional.

In view of above shortcomings, the application for issuance of FSC is rejected. The occupancy in the building without requisite fire safety arrangement shall be at risk and liability of owner /occupier of the building. The statutory /licensing authority may take necessary action as deemed fit.

Yours faithfully

(Atul Garg)

DIRECTOR

Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. AE. CPWD, Lady Harding Hospital, New Delhi.