

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजमीन
अमृत महीरसा

No. F6/DFS/MS/Industrial/SZ/2024/ 356(A)

Dated: 24/06/2024

To,

The Authorized Signatory,
M/s Supreme Impex,
Plot no. D- 107-108,
Okhla Industrial Area, Phase-I, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Supreme Impex, located at Plot no. D- 107-108, Okhla Industrial Area, Phase-I, New Delhi.

Sir,

With reference to your email dated 30.05.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 20.06.2024 in the presence of Sh. U. S. Lakhera (Admin.) and it was observed that the building is comprised of Basements + Ground + 03 upper floors. During the inspection following shortcomings were observed:

1. 2 nos. of staircases 1.50 meters width each not provided in the building.
2. Alternate staircase in basement found blocked.
3. Fire check door (FCD) found removed at all floors.
4. Exhaust system in basement found non functional.
5. Hose reels found non functional.
6. Automatic Fire Detection and Alarm System (ADAS) found non functional.
7. Manual Operated Electrical Fire Alarm System (MOEFA) found non functional.
8. Sprinkler system found non functional.
9. Internal & yard hydrant found non functional.
10. Fire pumps found non functional.
11. Exit sinages found removed.
12. PVC roofing on temporary construction on terrace must be replaced by non combustible material.
13. The ventilation stalboards covered by plywood in basement shall be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)

Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.