



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/1423

Dated: 01/07/2024

To

The Dy. Director (Infrastructure.),
The Institute of Cost Accountants of India,
CMA Bhawan, 3, Institutional Area,
Lodhi Road, New Delhi-110003

Sub: Regarding renewal of Fire NOC of "The Institute of Cost Accountants of India" CMA Bhawan, 3, Institutional Area, Lodhi Road, New Delhi.

Sir,

This has reference to letter No. ICMAI/Infrastructure/Delhi/5/2024 dated 27th May, 2024. In this connection, the said premise was visited by the concerned officers of this department on dated 20/06/2024 to verify the compliance of shortcomings already communicated by this office vide letter No. F6/DFS/MS/2022/732 dated 01/04/2022 and observed no progress/compliance except the one mentioned at serial no. 2 of said letter (copy enclosed). In addition to the existing shortcomings, the following is also observed.

1. Conference/lecture room found established in basement having single exit/stair.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the managements.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg.), New Delhi Municipal Council, Sansad Marg, Palika Kendra, New Delhi-110001.