

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/Business/2024/SZ/ 364

Dated: 27/06/2024

To

Mr. Dinesh Rajoriya (DGM/Electrical)
IRCON infrastructure & Service Limited,
Department Of Science and Technology Bhawan,
New Mehrauli Road, New Delhi 110016.

Sub.-: Regarding grant of Fire Safety Certificate in r/o M/s Department Of Science And Technology (Integrated Office Building) Block- 2 at Plot No C-2, Qutab Institutional Area, Shaheed Jeet Singh Marg, New Delhi

Sir,

This has reference to with Email dated 15/05/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.06.2024 in the presence of Mr. Dinesh Rajoriya (DGM/Electrical) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The pressurization of staircase & lift lobbies non functional.
2. Fire fighting pumps not on auto mode.
3. Exit signage's found removed at some strategic locations.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg Department) MCD, Green Park zone, New Delhi-16