



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 11000



No. F.6/DFS/MS/BP/2024/ 321

Dated: 10/06/2024

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
New Delhi- 110002.

Sub:- Rejection of building plans from fire safety point of view in r/o Addition / alteration in industrial building at Plot no. G-32, Narela Industrial Area, Delhi- 110040.

Sir,

With reference to your online request ID no. 10118756 dated 31.05.2024 on the subject cited above; it is informed that the referred online existing building plans in respect of Addition / alteration in industrial building at Plot no. G-32, Narela Industrial Area, Delhi-110040 were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. The height of Moderate Hazard industrial occupancy is beyond 18 meter.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above mentioned shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director

C. X. W.