

C-89.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 365

Dated: 26/06/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Indraprastha located at Ground, 1st, 2nd & 3rd floor 17A/54, WEA Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024060408724, dated 04/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 20/06/2024 in the presence of Sh. Rakesh Sharma (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire check doors found not provided.
2. Terrace pump found nonfunctional on auto mode.
3. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
OK
26/6/24

Copy to: - The Manager, M/s Hotel Indraprastha located at Ground, 1st, 2nd & 3rd floor
17A/54, WEA Karol Bagh, New Delhi - 110005.