



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

RF/DFA

No. F6 /DFS/MS/Industrial/SZ/2024/ 367

Dated: 28/06/2024

To,

The Owner/occupier,  
M/s Motherson Auto Limited,  
Plot No. F-7, Block B-1, Mohan Cooperative, Industrial Estate,  
Mathura Road, New Delhi.

**Sub:** - Regarding renewal of Fire Safety Certificate in r/o **M/s Motherson Auto Limited** located at **Plot No. F-7, Block B-1, Mohan Cooperative, Industrial Estate, Mathura Road, New Delhi.**

Sir,

With reference to the your letter bearing outdoor diary no. 2655 dated 07.06.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 24.06.2024 in the presence of Mr. Narender (Maintenance Supervisor) and it was observed that the building is comprised of Basements + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire check door (FCD) found removed.
2. Vertical opening not sealed.
3. Electrical room in basement not segregated.
4. No lift lobby in basement & upper floors.
5. Water based fixed fire installations like Hose reels, Internal hydrants, Sprinklers etc. were found non functional.
6. 20,000 liters capacity of terrace tank found not provided.
7. Terrace fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service

25/6/24

**Copy to:-**

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.