

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2024/ 366

Dated: 28/06/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 3 or 4, Block H
,Bali Nagar, New Delhi-110015

Sir,

Please refer your online request ID No.-10118580 dated 20/06/2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of construction of institutional (Hospital) building at Plot No. – 3&4, Block H, Bali Nagar, New Delhi-110015.

Following shortcoming is observed:

1. Staircase is not segregated at ground floor as per clause 7.11(t) of UBBL-16.
2. Exit is passing through another unit which is not allowed as per clause 7.5.10 of UBBL – 2016.
3. Corridors/passageway is not proposed as per clause 7.11.2(e) of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director

011-23414000

u e s