

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2024/SZ/ 367

Dated 26/06 /2024

To

The Joint Commissioner of Police,
Lic / Branch, 1st floor, Police Station
Defence Colony, New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s SHALIMARR Hotel at Plot No A-160, Road No 4, Mahipalpur New Delhi 110037.

Sir,

This has reference to with **MHA Portal ID No 2024052908346** dated **29/05/2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21/06/2024 in the presence of Mr. Diwaker (Manager) to verify the fire safety arrangements installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Smoke management system not provided in the building as per clause 7.31 of UBBL 2016.
- 2 First aid hose reel provided but found nonfunctional.
- 3 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 4 Automatic sprinkler system provided but found nonfunctional
- 5 Terrace level Fire fighting pump capacity 900 LPM provided but found nonfunctional.
- 6 Exit signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 607 dated 15/12/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
