

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/379
To

Dated: 28/06.../2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s BMK Guest House, B-2, Greater Kailash
Enclave-1, New Delhi 110048

Sir,

This has reference with **MHA Portal ID 2024060508812 dated 07/06/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.06.2024 in the presence of Mr. Jitender Kumar and to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground plus three upper floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found nonfunctional.
2. MOEFA not working.
3. Automatic sprinkler system provided but found nonfunctional.
4. Fire fighting pumps provided but found nonfunctional.
5. Exit signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE