

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



NO. F-6/DFS/MS/EH/WZ/2024/ 267

Dated:- 28/06/2024

To,

Smt. Ashima Bhatia,
M/s. Delikat Hospitality Pvt. Ltd.,
172, G.F., Kapil Vihar,
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Delikat Hospitality Pvt. Ltd.
Located at 172, G.F., Kapil Vihar, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024060308693 dated 03.06.2024 on the subject cited above. Above said eating house is running at ground floor in a building comprised of basement, stilt, ground plus two upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department on 25.06.2024 in presence of Sh. Ajay Bhatia to check the fire safety measures provided in the building.

During the course of inspection following shortcomings have been observed:-

- 1 First aid hose reel found provided but not functional.
- 2 MOEFA found provided but not functional.
- 3 Internal hydrant found provided but not functional.
- 4 Terrace level pump not found in automation.
- 5 Over head tank capacity found 10,000 liters against the required quantity of 20,000 liters.
- 6 Exit signage's not provided.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully


Atul Garg
Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024060308693.