

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/EH/2024/SZ/ 269

Dated:- 28/06/2024

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Heisetasse Beverages Pvt Ltd, located at, M-44, M Block, Greater Kailash-II, New Delhi 110048.

Sir,

This has reference to your MHA Portal No. 20240611090180 dated 11/06/2024 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26.06.2024 in the presence of Ms. Hema (Manager) to verify the fire safety measures installed in the building and observed that the restaurant running at GF & Mezzanine Floor only. During inspection, following points were observed:

1. There is one staircase having width of 1.50 mtr against the required two staircases having width of 1.50 mtr & 0.92 mtr respectively.
2. Exit Signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 70 dated 07/02/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]