



75
Azadi Ka
Amrit Mahotsav

279

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2024/ 268

Dated: 28/06 /2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s HMS Host Hospitality Services Bharat Pvt. Ltd. at DP-12, Domestic Departure Junction, Terminal-3, IGI Airport, New Delhi-110037

Sir,

This has reference to online MHA ID No. 2024060708966 dated 07/06/2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the concerned officers of this department on dated 20/06/2024 to verify status of the fire safety arrangements provided therein. Sh. Manik Mehra (DGM) & Sh. Vinay Kumar (Asst. Manager) was present at the time of inspection. During the inspection, the shortcomings observed are as below.

1. Alternate exit found blocked and space encroached with chairs & table for customers.
2. Smoke check door not provided to segregate electrical panel room and store area.
3. The exit signage found removed at some places.

Keeping in view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements/certificate shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

01/06/24

Copy to: -

1. The Dy. Health Officer, Municipal Corporation of Delhi, Najafgarh Zone near Dhansa Bus Stand, Najafgarh, New Delhi-110043
2. Authorized Signatory, M/s HMS Host Hospitality Services Bharat Pvt. Ltd., DP-12, Domestic Departure Junction, Terminal-3, IGI Airport, New Delhi-110037