



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2024/ 262

Dated: 26/06/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s SANA DI GE (A unit of Goldfinch Hotels Pvt. Ltd), Shop No. 12/48, Ground, First & Second Floor, Commercial Complex, Malcha Marg, Chanakyapuri, New Delhi-110021

Sir,

This has reference to online MHA ID No. 2024061009178 dated 10/06/2024 & 2024032203438 dated 31/05/2024, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned by this department on dated 18/06/2024 to verify the availability and operability of the fire safety arrangements provided therein. Sh. Arun Kumar (Purchase Manager) and other staff was present at the time of inspection. During the inspection, the shortcomings observed are as below.

1. One of the staircases/exits in basement found blocked.
2. First aid hose-reel found provided but non-functional and without nozzle.
3. Terrace pump was not on auto mode.
4. The exit signage found removed at some places.

Keeping in view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements/certificate shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Medical Officer of Health, New Delhi Municipal Council, Sansad Marg, Palika Kendra, New Delhi-110001
2. Authorized Signatory, M/s SANA DI GE (A unit of Goldfinch Hotels Pvt. Ltd), Shop No. 12/48, Ground, First & Second Floor, Commercial Complex, Malcha Marg, Chanakyapuri, New Delhi-110021