

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/6
आजादी का
अमृत महोत्सव

C/61

No. F6 /DFS/MS/Industrial/SZ/2024/ 371

Dated: 27/06/2024

To,

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s McDonald's Family Restaurant (M/s Connaught Plaza Restaurant Pvt. Ltd.) located at Ground floor, Shop no. 2 & 3, Eros Cinema Building, Jangpura Extension, New Delhi-14.

Sir,

With reference to the MHA online application no. 2024060508832 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 20.06.2024 in the presence of Mr. Rohit (Manager) and it was observed that the restaurant is running on ground floor of the building which is comprised of Two tier Basement + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. The alternate exit width of minimum 1.45 meters shall be provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)

Director

Delhi Fire Service

DL
20/6/24

N