

5/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/SZ/2024/ 266

Dated 28/06/2024

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Trinandrews A unit of Tera Hotels, located at Shop No. B-1/637, GF, Janakpuri, New Delhi- 110058.

Sir,

Please refer to online application ID 2024052208041 dated 27.05.2024, on the subject cited above. In this connection, it is to inform you that the above said eating house running at ground floor (restaurant) and first floor (kitchen) of a building comprised of basement, ground plus three upper floors. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 11.06.2024 in presence of Sh. Ramandeep Singh (Manager).

During the course of inspection, the following shortcomings have been observed: -

- 1 Three staircases having width of 1.18, 1.25 & 1.50 m found provided against requirement of two staircase with width of 1.50 m each from ground floor to first floor.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service
9/9-

Copy to-

1. The Owner/Occupier, M/s. Trinandrews A unit of Tera Hotels, located at Shop No. B-1/637, GF, Janakpuri, New Delhi- 110058.