

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 261  
To

Dated 26/06/2024

The Dy. Health Officer,  
Public Health Department, MCD,  
Aurobindo Marg, Green Park,  
New Delhi 110016.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s NAIVEDYAM located at First Floor, Synergy Building IIT Delhi Campus Hauz Khas, Delhi 110016

Sir,

This has reference to with **MHA Portal ID 2024053108556** dated **31/05/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.06.2024 in the presence of Mr. Akshay (Manager) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The premise is not accessible to Fire tender/fire engine.
2. There are two exit door having width of 1.50 mtr & 1.0 mtr against the required two exit door having width of 1.50 each.
3. First Aid Hose reel hose not provided.
4. Internal hydrants not provided.
5. Terrace level pump capacity 450 LPM provided but found not working.
6. Overhead tank capacity can't be check due to not accessible.
7. Exit signage not provided
8. The Hauz Khas Village have a single Entry/Exit road by which fire vehicles can go inside, however the vehicle cannot turn back/return to go for replenishment or other purposes as the road is not wide enough for turning.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL BARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police, Lic/Branch, 1<sup>st</sup> Floor, PS Defence Colony, New Delhi 110049