



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/EH//2024/WZ/ 247

Dated: 18/06/2024

To,

Sh. Naveen Mittal,
The Mohans (A Unit of Mittal Hotels Pvt. Ltd.),
Plot No. 3 & 4, 1st floor, Central Market,
Ashok Vihar, Delhi- 110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o The Mohans (A Unit of Mittal Hotels Pvt. Ltd.)

Sir,

This has reference to your online application received through MHA portal vide ID- 2024052007859 dated 30/05/2024 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 10/06/2024 in presence of Sh. R.k. Jha. Following shortcomings were observed at the time of inspection.

1. Smoke ventilation system found provided but not functional.
2. First aid hose reel found provided but not functional.
3. MOEFA found provided but not functional.
4. Internal hydrant found provided but not functional.
5. Pumping system not found in automation.
6. Exit signage found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

over 8

Copy to:-

1. The Dy. Health Officer, Keshavpuram Zone, A-1, Public Health Department, MCD, Keshavpuram, New Delhi-110035.
2. MHA Online ID No. 2024052007859 dated 30/05/2024.