

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2024/SZ/255

Dated: 24/06/2024

To

The Addl. Commissioner (Lic/Branch)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi 110049

Subject: Regarding issuance of FSC in r/o **M/s Adyar Ananda Bhavan Sweet India Pvt. Ltd** located at **GF, FF & SF**, S-16, Green Park Street, Main Market, New Delhi-110016.

Sir,

This has a reference to MHA Portal No **2024052408129** dated **24.05.2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 10.06.2024 in the presence of Mr. Bala Ji to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The entry / exit of rear side staircase is through a kitchen, which is not acceptable.
2. Internal hydrants not provided.
3. The Exit signage's not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

*[Handwritten signature]*