

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 377

Dated: 28/06 /2024

To

The Principal,
Sarvodaya Kanya Vidyalaya No 2,
Mehrauli, Main Bazar New Delhi -110030

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Sarvodaya Kanya Vidyalaya No 2, Mehrauli, Main Bazar New Delhi -110030 (ID- 1923079)

Sir,

This has reference to with your letter no SKV/No-2/Meh/2024//09 dated 07/06/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 26.06.2024 in the presence of Mr. Raj pal Yadav (Estate Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found nonfunctional.
2. Fire fighting pumps provided but found nonfunctional.
3. Overhead tank capacity 10,000 ltrs found empty.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

