



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/Ind./ 362

Dated: 27/06/2024

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: Regarding issuance of Fire Safety Certificate in r/o Akshaya Patra (Industrial Kitchen) located at Plot No. D-27, SMA, Industrial Area, Jahangirpuri, Delhi-110033.

Sir,

This has reference to online mha portal I'd. No. 2024052208025 dated: 07.06.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 21.06.2024 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no F6/DFS/MS/BP/2013/303 dated 03.10.2013. At the time of inspection Sh. Siddharth Mathur (Manager) was also present at site. During the course of the inspection it is observed that the building was comprised of basement, ground & 03 upper floors but (industrial kitchen is running on ground floor only). Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors is not provided.
2. Smoke ventilation system is not provided in basement.
3. Hose reel hose provided but not functional.
4. Smoke detection system is provided but not functional.
5. MOEFA system is provided but not functional.
6. Sprinkler systems is provided in the basement & all upper floors but found not functional.
7. Internal hydrants & yard hydrant is provided but found not functional.
8. Electrical driven fire pump capacity of 2280lpm, Diesel engine pump capacity of 2280lpm, Jockey Pump 180lpm & terrace level fire pump capacity of 900lpm is provided but not functional and damaged condition.
9. Terrace level fire water tank capacity of 20,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
10. Exit & floors signage's not provided in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of industrial kitchen is at your own risk & responsibility.

Yours faithfully,

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Commissioner of Factory licensing, DMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002.