

485

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ GH/ 384

DATED: 02/07/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/S Cosmo Guest House, Located at 7A/40 WEA, Channa Market, Karol Bagh, New Delhi.

Sir,

Please refer to online application No. 20244060809055, dated 08/06/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 26/06/2024 in the presence of Sh. Rakesh Kumar (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system for upper floor found inadequate/ non functional.
2. The Basement found Closed.
3. The MOEFA found nonfunctional.
4. Alarm system in lift car found nonfunctional.
5. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service.

Copy to:-

1. The Manager, M/S Cosmo Guest House, Located at 7A/40 WEA, Channa Market, Karol Bagh, New Delhi - 110005.