

398

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 398

Dated: 05/07/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Gold Souk located at 7A/35, WEA Channa Market, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024060809042, dated 08/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 26/06/2024 in the presence of Sh. Jitender Mishra (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. The Smoke management System found removed in basement.
2. Hose reel hose found nonfunctional.
3. MOEFA & P A System found nonfunctional
4. Automatic sprinkler system found nonfunctional in basement.
5. Terrace pump of 450 lpm capacity found nonfunctional.
6. Exit signage found removed at some places
7. The basement was found being used as meeting hall/ party hall.
8. Atrium found covered.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to: - The Manager, M/s Hotel Gold Souk located at 7A/35, WEA Channa Market, Karol Bagh, New Delhi - 110005