

C-71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 375

Dated: 28/06/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Grand Central (A unit of Picasso Enterprises Pvt. Ltd.) located at 1st, 2nd & 3rd floor 15A/32, WEA Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024052708229, dated 03/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 24/06/2024 in the presence of Sh. Rahul Kumar (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. Ventilation system not provided in common area.
3. CO detectors found not provided.
4. Pressure gauge installed near pump found removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Gang)

Director

Delhi Fire Service

ok

Copy to: - The Manager, M/s Hotel Grand Central (A unit of Picasso Enterprises Pvt. Ltd.) located at 1st, 2nd & 3rd floor 15A/32, WEA Karol Bagh, New Delhi - 110005.