



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 376

Dated: 04/07/2024

To

The General Manager & Dy. Zonal Head,
Delhi Zone. IDBI Bank, 9th Floor, Plate-B,
Block-2, NBCC Office Complex,
East Kidwai Nagar, New Delhi-110023

Sub: Regarding issuance of Fire NOC in r/o Fit-Out Work in the Office Space of IDBI Bank at 9th Floor, Plate-B & 8th Floor, Plate-A&B, Block-2, NBCC Office Complex, East Kidwai Nagar, New Delhi-110023

Sir,

This has reference to your letter No. IDBI Bank/ZO/IMD/FIRENOC/003 dated 03/05/2024 received through outdoor diary No. 3069 dated 18/06/2024, on the subject cited above. In this connection, the premise was re-visited by the officers concerned of this department on 29/06/2024 to verify the compliance of shortcomings issued by this office vide even letter No. 162 dated 02/04/2024. Mr. Sanjeev Kumar (Security Officer) was present during the inspection. It was observed that the shortcomings mentioned at serial No. 2, 4, 5 & 6 of said letter are only complied. Thus, the left-over shortcomings as mentioned below are yet to be complied.

1. The Fire Check Door (FCDs) shall be provided in server room.
2. The detectors found removed in some offices, record room & conference room.
3. MCPs shall be increased/ provided in left out areas.
4. System not integrated i.e. ventilation system with MCPs.

Keeping in view of the above, the application for issuance of clearance from fire safety and escape point of view is rejected. You are again advised to rectify all the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE



Copy to: -

1. The CGM/Engg. NBCC Services Limited, Ground Floor, Tower-4, Office Block, Along Ring Road, East Kidwai Nagar, New Delhi-110023