

GJ)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 397

Dated: 08/07/2024

To,

The Manager,
Mata Leelawati Saraswati Vidya Mandir,
H-16, Hari Nagar (Near DDU Hospital), New Delhi-110064.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Mata Leelawati Saraswati Vidya Mandir, H-16, Hari Nagar (Near DDU Hospital), New Delhi-110064.

Sir,

Please refer to your letter No. MLSVM/2024-25/30 dated 30.05.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 03.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Renu Sharma (Principal) was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings-

1. Passage of Multipurpose Hall found blocked by the chairs and music system and it should be open in school time.
2. Hose reel found provided but not functional.
3. Terrace fire pump 450 LPM found provided but not functional.
4. Exit signage's found removed.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Atul Garg)

Director

Delhi Fire Service



Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.