



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 381

Dated: 08 07 /2024

To

Sh. Vasu Garg (Director),
M/s Oncoplus Hospital (A unit of Deep Chand Oncology Services Pvt. Ltd),
Plot No. B-73, Defence Colony,
New Delhi-110024

Sub: Regarding revoke of order for suspension of Fire Safety Certificate in r/o M/s Oncoplus Hospital (A unit of Deep Chand Oncology Services Pvt. Ltd), Plot No. B-73, Defence Colony, Delhi.

Sir,

This has reference to your letter No. Nil received from dated 11/06/2024, on the subject cited above. In this connection, the premise has been inspected by the officers concerned of this department on 27/06/2024 from fire safety & escape point of view. Sh. Amit Garg (owner/occupier) and other staff was present at the time of inspection. During the inspection, the shortcomings observed are as below.

1. The electrical shaft found unsealed.
2. The over-head water storage tank of 10,000 liters found removed & replaced with a tank of 5,000 liters capacity.
3. Temporary structure at terrace still exists and being used as kitchen, despite submitting a notarized affidavit dated 01/09/2022 regarding removal within one month.

In view of above, the application for revoke of order for suspension of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE