



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 373

Dated: 03/07/2024

To

The Executive Engineer (E),
SJHED Central Public Works Department,
Safdarjung Hospital Complex,
Ring Road, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o O.T. Block, Safdarjung Hospital Complex, Ring Road, New Delhi-110029

Sir,

This has reference to your letter No. 19(1)/DB/SJHED/2024-25/665 dated 28/05/2024 received through outdoor diary No. 2379 dated 03/06/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 22/06/2024 in the presence of Mr. Vivek Gupta (JE/Elect). During the course of inspection, the shortcomings observed are as below.

1. One of the staircases found obstructed by AC unit/installation.
2. The first-aid hose-reel found non-functional.
3. Automatic fire detectors found non-functional at some places.
4. MOEFA/MCPs found non-functional at some places.
5. Hose-boxes near yard hydrant found empty i.e. without hoses & branch.
6. The standby fire pump found non-functional.
7. Fireman's grounding switch found defective/non-functional.
8. Lift signage found removed.
9. Lots of waste material/old furniture found lying at terrace, which is hazardous from fire safety point of view.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital Complex, Ring Road, New Delhi-110029