

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2024/ 375

Dated 04.07.2024

To,

Asst. General Manager (P. &E),
L.H.O. S.B. I, 11 Sansad Marg,
New Delhi.

Sub:- Regarding renewal of FSC in r/o State Bank Of India, 11 Sansad Marg, New Delhi.

Sir,

This has reference to your letter no. letter no. nil dated 11.06.2024, on the subject cited above. In this connection, it is to inform that the site (D- block) was inspected by the officers concerned of this department on 25/06/24 in the presence of **Sh. Geetam Singh, Fire Officer** and the following shortcomings were observed:

1. Detectors found nonfunctional at some places and found removed at some floors in common area.
2. PA system found nonfunctional.
3. Corridor found encroached by dumping of almiraha and other items which may create obstacle to freely evacuation the occupants in case of emergency.
4. 10th floor found under renovation and fire fighting system such as detectors found removed. .
5. All wooden paneling used in the corridor/offices in the way of means of escape shall be treated with fire retardant paint.

In view of above, the FSC cannot be renewed. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

1. The Chairman, NDMC, Palika Kendra, New Delhi.