



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 375

Dated:03/07/2024

To

The Executive Engineer (E), SJHED Central Public Works Department, Safdarjung Hospital Complex, Ring Road, New Delhi–110029

Sub: Renewal of Fire Safety Certificate in r/o Sports Injury Centre, Safdarjung Hospital Complex, Ring Road, New Delhi-110029

Sir,

This has reference to your letter No. 19(1)/DB/SJHED/2024-25/665 dated 28/05/2024 received through outdoor diary No. 2379 dated 03/06/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 22/06/2024 in the presence of Mr. Vivek Kumar Gupta (JE/Elect). During the inspection, shortcomings observed are as below.

- 1. One of the staircases found locked & blocked.
- 2. First-aid hose reels provided found non-functional.
- 3. PA System provided found non-functional.
- 4. Automatic starting of fire pumps at ground level found non-functional.
- 5. Terrace pump could not be checked as the access to pump was obstructed by waste material.
- 6. Waste material & dismantled items stored/lying unmannerly in basement shall cause safety & safe evacuation of occupants in case of an emergency.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

DIRECTOR
DELHI FIRE SERVICE

81L88

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital Complex, Ring Road, New Delhi-110029