

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hospital/2024/SZ/377  
To

Dated 04/07/2024

Mr. Dileep Makhija,  
Nursing Home, (The Neptune Hospital)  
Plot No B-2/5, Safdarjung Enclave,  
New Delhi-110029

Sub: -Regarding renewal of Fire Safety Certificate in r/o Nursing Home in the name of "The Neptune Hospital" at Plot No B-2/5, Safdarjung Enclave, New Delhi-110029

Sir,

This has reference with letter nil dated 13/06/2024, received through outdoor diary no 3009 dated 14/06/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.07.2024 to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 The Stilt floor of the building is being using for triage emergency patient bedded facility and storage of liquid oxygen battery / manifold services. The use of stilt floor shall be restricted to the activity as per permissible services as per UBBL - 2016.
- 2 The Exit signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer Bldg Department, Green Park Zone, New Delhi 110016