

5.11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ CONGT / 84

Dated: 05/07/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Issuance of Fire Safety Certificate in r/o The Royal (A Unit of Lalit Electrical) Located at Kh. No16/7&16/8 Pochanpur Extn. Dwarka Sector - 23, New Delhi - 110075.

Sir,

Please refer to online application No. 2024041304952 dated 11/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 26/06/2024 in the presence of Sh. Neeraj Kumar (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Only one staircase of 1.5m width found provided against required 02 staircases of 1.5m and 2 m clear width.
2. Hose reel hose found not provided.
3. Terrace pump of 450 lpm capacity found nonfunctional.
4. Fire water tank of 20000 ltr capacity found not provided.
5. Exit signage found not provided.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
o/c. 

Copy to: - The Manager, M/s The Royal (A Unit of Lalit Electrical) Located at Kh. No16/7&16/8 Pochanpur Extn. Dwarka Sector - 23, New Delhi - 110075.