

C/132

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ GH | 382

Dated: 02/07/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Twin Tree Guest House (a unit of M/s Farsight Hospitality Pvt. Ltd.) located at A-19 Naraina Vihar New Delhi-110028.

Sir,

Please refer to online application No. 20244060608857, dated 06/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 26/06/2024 in the presence of Sh. Chetan Vats (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system for basement & upper floor found inadequate/ non functional
2. Hose reel hose found nonfunctional.
3. Automatic sprinkler system found nonfunctional in basement.
4. Terrace pump of 450 lpm capacity found nonfunctional & one pump found removed.
5. Exit signage found removed at some places
6. The lift found running from basement to upper floors it must be segregated by Fire Check Doors in basement.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
OK 27/6/24

Copy to: - The Manager, M/s Twin Tree Guest House (a unit of M/s Farsight Hospitality Pvt. Ltd.) located at A-19 Naraina Vihar New Delhi-110028.