



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2024/ 403

Dated: 08/07/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station,
Defence Colony, New Delhi.

Sub:- Regarding grant of Fire Safety Certificate in r/o M/s A.R. Residency located at **Property no. 389, Bauligate Basti, Nizamuddin, New Delhi.**

Sir,

With reference to the MHA online application no. 2024050106612 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 03.07.2024 in the presence of Mohd. Shanwaz (Manager) and it was observed that the building is comprised of Ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. 8 nos. of fire extinguishers found not provided.
2. 2 nos. of staircases having width of 1.50 meters each not provided.
3. Hose reels found not provided.
4. CO detectors not provided as per clause 7.31.viii, of UBBL 2016.
5. Fire pumps found not provided.
6. Terrace tank capacity of 5,000 liters not providing.
7. Ext sinages fount not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Bl w