



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 393

Dated: 04/07/2024

To,

Mr. Yash Pal Singh (Principal),
D.A.V. Sr. Secondary School,
Shankar Nagar, Delhi - 110051.

Subject: - Regarding grant of Fire Safety Certificate in r/o D.A.V. Sr. Secondary School, Shankar Nagar, Delhi - 110051, Delhi - 110090.

Sir,

This has a reference to your outdoor dairy no Nil dated 07/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/06/2024 in the presence of Mr. Yash Pal Singh (Principal) and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. Two staircases of width 1.70 meter and 1.40 meters are provided instead of required width of 1.50 meter each.
2. First-Aid-Hose Reel not provided.
3. MOEFA not provided.
4. Internal Hydrant not provided.
5. Fire pump of 450 LPM not provided.
6. Overhead tank not provided.
7. Exit signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.