



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आफादी व
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2024/ 281

Dated: 08/07/2024

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Fabcafe Foods Pvt. Ltd. located at 44 Ring Road, Lajpat Nagar – III, New Delhi.

Sir,

With reference to the MHA online application I.D. no. 2024061209238 on the subject cited above, it is informed that the said restaurant was inspected by a team of offices concerned from this department on 03.07.2024 in the presence of Mr. Sunil Chauhan and it was observed that the restaurant is running at Upper Ground floor of the building is comprised of Basement + Stilt + Upper ground + 03 upper floors. During the inspection the following shortcomings were observed:

1. First aid hose reel found non functional.
2. Down comer system found non functional.
3. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

03/7/24