

c/44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/SZ/2024/ 273

Dated 04/07/2024

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Gola Sizzlers Pvt. Ltd., Unit No. A-1, J-1/64, ground floor, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to online application ID 2023071112355 dated 06.06.2024, on the subject cited above. In this connection, it is to inform you that the above said eating house/restaurant running at first floor only of a building comprised of ground plus one upper floor. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 28.06.2024 in presence of Ms. Archana (Manager).

During the course of inspection, the following shortcomings have been observed: -

- 1 Hose reels/Hydrant found provided but not functional.
- 2 Terrace fire pump capacity of 450 LPM found provided but not functional.
- 3 Overhead water storage tank of 20,000 ltrs provided but found broken and empty
- 4 Exit Signage found removed.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to-

1. The Owner/Occupier, M/s. Gola Sizzlers Pvt. Ltd., Unit No. A-1, J-1/64, ground floor, Rajouri Garden, New Delhi-110027.