



Dated: 04/07/2024

No. F6/DFS/MS/School/NDZ/2024/ 380

To,

Mr. Deepak Singh (Manager),
Indal Memorial Public School,
Main Road, Kondli,
Delhi - 110096.

Subject: - Regarding grant of Fire Safety Certificate in r/o Indal Memorial Public School located at Main Road, Kondli, Delhi - 110096.

Sir,

This has a reference to your outdoor dairy no. 2790 dated 11/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24/06/2024 in the presence of Mr. Deepak Singh (Manager), and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. The Premises in not accessible to fire engines.
2. One staircases of width 1.10 meter are provided against the requirement of width 1.50 meter each.
3. The width of corridor is 1.40 meter against the requirement of 1.50 meters.
4. The class room door size is 0.90 meter against the requirement of 1.0 meter.
5. Fire Extinguisher not provided.
6. First-Aid-Hose Reel not provided.
7. Fire pump of 450 LPM not provided.
8. Overhead tank not provided.
9. Exit signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

0/0 DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, MCD, Udyog Sadan, Plot No. 419, FIE, Patparganj, Delhi - 110092.