

0/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/SZ/2024/ 272

Dated 04/07/2024

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Kali Ghata Misthan Bhandar Pvt. Ltd., located at F-146, GF, Arya Samaj Road, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to online application ID 2023071112355 dated 06.06.2024, on the subject cited above. In this connection, it is to inform you that the above said eating house/restaurant running at first floor only of a building comprised of ground plus two upper floors. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on dated 28.06.2024 in presence of Sh. Naveen Kumar Gupta (Owner/occupier).

During the course of inspection, the following shortcomings have been observed: -

- 1 Two staircases having width of 1.5 & 1.0 m found provided against requirement of two staircase with width of 1.50 m each.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully


(Atul Garg)

Director
Delhi Fire Service

Copy to-

1. The Owner/Occupier, M/s. Kali Ghata Misthan Bhandar Pvt. Ltd., located at F-146, GF, Arya Samaj Road, Uttam Nagar, New Delhi-110059.