

C/27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 382

Dated: 04/07/2024

To,

The Manager,  
Kalinga Institute of Social Science Delhi Government Sr.  
Secondary Residential School, Issapur, New Delhi-110073.

**Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M/s. Kalinga Institute of Social Science Delhi Government Sr. Secondary Residential School, Issapur, New Delhi-110073.**

Sir,

Please refer to your letter received on dated 08.06.2024 through online email Id [25426@cbseshiksha.in](mailto:25426@cbseshiksha.in), on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 28.06.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Pardeep Sharma was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings: -

1. First aid hose reels/hydrant found provided but not functional.
2. Two no's Fire pumps capacity of 450 LPM each found provided but not functional in auto mode.
3. Exit signage's found removed.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.