

clm

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 378

Dated: 04/07/2024

To,

The Manager,
Rama Public School, Plot No.-18, B-Block,
Gopal Nagar, Najafgarh, New Delhi-110043.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Rama Public School, Plot No.-18, B-Block, Gopal Nagar, Najafgarh, New Delhi-110043.

Sir,

Please refer to your letter No. RPS//2024-25 dated 03.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 27.06.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Kuldeep Gupta (Manager) was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings: -

1. Second staircase/fire escape route found blocked at all floor level.
2. Hose reel found provided but not functional.
3. Terrace fire pump 450 LPM found provided but not functional in auto mode.
4. Exit signage's are provided but not sufficient.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.