



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/3
आशादी का
अमृत महोत्सव

Dated: 04/07/2024

No. F6/DFS/MS/School/NDZ/2024/ 381

To,

The Principal,
Sarvodaya Kanya Vidhyalya
DDA Flats, East of Loni Road,
Delhi - 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sarvodaya Kanya Vidhyalya located at DDA Flats, East of Loni Road, Delhi - 110093.

Sir,

This has a reference to your email dated 26/03/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 25/06/2024 in the presence of Mr. Keshav Sharma (Estate Manager) and observed that building comprised of G + 3 (two Separate blocks) New Building Block.

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(APUL GARG)
DIRECTOR

OK DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Sarvodaya Kanya Vidhyalya located at DDA Flats, East of Loni Road, Delhi - 110093.